

****PUBLIC WATER SYSTEM MUST APPROPRIATELY MODIFY THIS PUBLIC NOTICE TO INCLUDE UP-TO-DATE INFORMATION REGARDING THE VIOLATION AS WELL AS INFORMATION ABOUT THE CURRENT STATUS OF THE VIOLATION'S AFFECT ON THE WATER SYSTEM. PUBLIC WATER SYSTEM OFFICIAL MUST DELETE THIS PARAGRAPH ONCE PUBLIC NOTICE HAS BEEN APPROPRIATELY UPDATED, PRIOR TO SENDING OUT TO THE PUBLIC****

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monthly Reporting Requirements Not Being Met By Timberon W&SD

Our water system recently violated a drinking water regulation. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

We are required to submit turbidity data and chlorine levels to the State on a monthly basis. This requirement has not been met for the month(s) of: November 2024

What does this mean?

This is not an emergency. If it had been you would have been notified immediately.

Monitoring and reporting turbidity and chlorine levels in your water are important in ensuring safe water to all our customers. **Chlorine is added to the water to inactivate bacteria that may be present. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.** These symptoms are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice.

Tests taken during this time period did / did not indicate the presence of bacteria in the drinking water system during this period.

What should I do?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, please contact your health care professional.

What is being done? [Describe corrective action.]

Chlorine is Tested Daily

We anticipate resolving the problem within 90 Days

For more information, please contact: (575-987-2250
Timberon W&SD NM3546419
PO Box 40,
Timberon, NM 88350

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monthly Disinfection Requirements Not Being Met By Timberon W&SD

Our water system recently violated a drinking water regulation. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

We are required to maintain inactivation of pathogens entering the distribution system. Our disinfection requirement has not been met for the month(s) of: November 2024

What does this mean?

This is not an emergency. If it had been you would have been notified immediately.

Complete inactivation of pathogens in your water are important in ensuring safe water to all our customers. This is required in addition to adding chlorine to the water. **Chlorine is added to the water to inactivate bacteria that may be present. Lack of adequate disinfectant may cause the presence of disease causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.** These symptoms are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice.

Tests taken during this time period did / did not indicate the presence of bacteria in the drinking water system during this period.

What should I do?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, please contact your health care professional.

What is being done? [Describe corrective action.]

~ Chlorine added to Water Per State Guidelines

We anticipate resolving the problem within 90 days

For more information, please contact: 575-987-2250
Timberon W&SD, NM3546419
PO Box 40,
Timberon, NM 88350

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

****PUBLIC WATER SYSTEM MUST APPROPRIATELY MODIFY THIS PUBLIC NOTICE TO INCLUDE UP-TO-DATE INFORMATION REGARDING THE VIOLATION AS WELL AS INFORMATION ABOUT THE CURRENT STATUS OF THE VIOLATION'S AFFECT ON THE WATER SYSTEM. PUBLIC WATER SYSTEM OFFICIAL MUST DELETE THIS PARAGRAPH ONCE PUBLIC NOTICE HAS BEEN APPROPRIATELY UPDATED, PRIOR TO SENDING OUT TO THE PUBLIC****

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monthly Reporting Requirements Not Being Met By Timberon W&SD

Our water system recently violated a drinking water regulation. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

We are required to submit turbidity data and chlorine levels to the State on a monthly basis. This requirement has not been met for the month(s) of: October 2024

What does this mean?

This is not an emergency. If it had been you would have been notified immediately.

Monitoring and reporting turbidity and chlorine levels in your water are important in ensuring safe water to all our customers. **Chlorine is added to the water to inactivate bacteria that may be present. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.** These symptoms are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice.

Tests taken during this time period did / ~~did not~~ indicate the presence of bacteria in the drinking water system during this period.

What should I do?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, please contact your health care professional.

What is being done? [Describe corrective action.]

Surface Water Plant was shut down on 12/10/24

We anticipate resolving the problem within 90 Days

For more information, please contact: 575-987-2250
Timberon W&SD NM3546419
PO Box 40,
Timberon, NM 88350

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Membrane Integrity Tests Requirements Not Met by Timberon W&SD

Our water system recently violated a drinking water regulation. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We are required to perform a daily membrane integrity test and test the membranes for safety after any turbidity exceedance. The test was not conducted in October 2024. Our membrane requirement had not been met.

What does this mean?

Membrane integrity testing ensures that the filtration of disease-causing organisms is effective. *Lack of adequate treatment may cause the presence of disease causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.* These symptoms are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice.

What should I do?

This is not an emergency. You do not need to boil your water or seek an alternate source. If you have specific health concerns, please contact your health care professional.

What is being done? [Describe corrective action.]

~ Surface Water Plant was shutdown on 12/10/24

We anticipate resolving the problem within 90 days

For more information, please contact: (575-987-2250

Timberon W&SD, NM3593821

PO Box 40

Timberon, NM 88350

Include email contact

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly. You can do this by posting this notice in a public place or distributing copies by hand or mail.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Membrane Integrity Tests Requirements Not Met by Timberon W&SD

Our water system recently violated a drinking water regulation. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We are required to perform a daily membrane integrity test and test the membranes for safety after any turbidity exceedance. The test was not conducted in December 2024. Our membrane requirement had not been met.

What does this mean?

Membrane integrity testing ensures that the filtration of disease-causing organisms is effective. *Lack of adequate treatment may cause the presence of disease causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.* These symptoms are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice.

What should I do?

This is not an emergency. You do not need to boil your water or seek an alternate source. If you have specific health concerns, please contact your health care professional.

What is being done? [Describe corrective action.]

- Surface Water Plant was shut down on 12/10/24.

We anticipate resolving the problem within 90 Days

For more information, please contact: 575-987-2250
Timberon W&SD, NM3593821
PO Box 40
Timberon, NM 88350

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly. You can do this by posting this notice in a public place or distributing copies by hand or mail.

****PUBLIC WATER SYSTEM MUST APPROPRIATELY MODIFY THIS PUBLIC NOTICE TO INCLUDE UP-TO-DATE INFORMATION REGARDING THE VIOLATION AS WELL AS INFORMATION ABOUT THE CURRENT STATUS OF THE VIOLATION'S AFFECT ON THE WATER SYSTEM. PUBLIC WATER SYSTEM OFFICIAL MUST DELETE THIS PARAGRAPH ONCE PUBLIC NOTICE HAS BEEN APPROPRIATELY UPDATED, PRIOR TO SENDING OUT TO THE PUBLIC****

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monthly Reporting Requirements Not Being Met by Timberon W&SD

Our water system recently violated a drinking water regulation. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

We are required to submit turbidity data, disinfection data, and chlorine levels to the State on a monthly basis. This requirement has not been met for the month of: December 2024

What does this mean?

This is not an emergency. If it had been you would have been notified immediately.

Monitoring and reporting turbidity and chlorine levels in your water are important in ensuring safe water to all our customers. *Chlorine is added to the water to inactivate bacteria that may be present. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. * These symptoms are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice.

Tests taken during this time period did / did not indicate the presence of bacteria in the drinking water system during this period.

What should I do?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, please contact your health care professional.

What is being done? [Describe corrective action.]

- Chlorine is Tested Daily
- Surface Water Plant was shut down on 12/10/24

We anticipate resolving the problem within 90 Days

For more information, please contact: TWSD office: 575-987-2250
Timberon W&SD NM3546419
PO Box 40,
Timberon, NM 88350

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Membrane Integrity Tests Requirements Not Met by Timberon W&SD

Our water system recently violated a drinking water regulation. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We are required to perform a daily membrane integrity test and test the membranes for safety after any turbidity exceedance. The test was not conducted in November 2024. Our membrane requirement had not been met.

What does this mean?

Membrane integrity testing ensures that the filtration of disease-causing organisms is effective. *Lack of adequate treatment may cause the presence of disease causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.* These symptoms are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice.

What should I do?

This is not an emergency. You do not need to boil your water or seek an alternate source. If you have specific health concerns, please contact your health care professional.

What is being done? [Describe corrective action.]

- Filtration Unit is Locked out right now

We anticipate resolving the problem within 90 days

For more information, please contact: 575-987-2250

Timberon W&SD, NM3593821

PO Box 40

Timberon, NM 88350

Include email contact

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly. You can do this by posting this notice in a public place or distributing copies by hand or mail.

****PUBLIC WATER SYSTEM MUST APPROPRIATELY MODIFY THIS PUBLIC NOTICE TO INCLUDE UP-TO-DATE INFORMATION REGARDING THE VIOLATION AS WELL AS INFORMATION ABOUT THE CURRENT STATUS OF THE VIOLATION'S EFFECT ON THE WATER SYSTEM. PUBLIC WATER SYSTEM OFFICIAL MUST DELETE THIS PARAGRAPH ONCE PUBLIC NOTICE HAS BEEN APPROPRIATELY UPDATED, PRIOR TO SENDING OUT TO THE PUBLIC****

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER SYSTEM

Timberon W and SD Failed to have an appropriate leveled certified operator for the drinking water system.

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda

Our water system recently violated a drinking water requirement. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we are doing to correct this situation.

New Mexico Regulations require all public water systems to be operated by an appropriate level of certified operator. We failed to meet this requirement by the New Mexico Environment Department's Drinking Water Bureau.

What should I do?

- There is nothing you need to do. You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at 1-800-426-4791.

What does this mean?

This is not an emergency. If it had been, you would have been notified within 24 hours.

What is being done? Preparing to test Again

We anticipate resolving the problem within 90 Days (or the problem was resolved on [give date]).

For more information, please contact:

575-987-2250
Timberon W and SD, NM3546419
PO Box 40
Timberon, NM 88350

**Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail. **

STATE OF NEW MEXICO
Water Quality Control Commission

This certifies that

Aaron M. Foster


Has met the requirement for the Utility Operator Certification adopted by the New Mexico Water Commission pursuant to the Utility Certification Act. NMAC 20.17.4.1 and is hereby certified as a Utility Operator authorized to perform as a

Water Supply 4

Certificate No.: 26279

Operator Certified since: 10/20/2022

Expiration Date: 08/31/2027



Signed for Chairman, WQCC

Pursuant to the NMED Delegation Order dated February 19, 2024, the Cabinet Secretary has delegated the authority to issue Utility Operator Certificates to DWB Bureau Chief. The DWB Bureau Chief has further delegated this authority to Utility Operator Certification Program Team Lead Eric Hall.

Walle Card—Tear HERE

NM Operator Identification

Operator ID Number: 19246

Operator Name: Aaron M. Foster

Certification Level (s): Water Supply 4

Date Issued: 08/13/2024

This card is required to identify your position and status as a certified operator when submitting potable water samples to laboratories in the State of New Mexico. You are required to provide this ID card along with a valid photo ID i.e. driver's license, when submitting a potable drinking water samples (Microbiological or Chemical/Radiological). This provides verification per the sampling Compliance Regulations, governing 'potable drinking water.'

This card is invalid if your certification becomes inactive, is suspended, revoked, canceled, or otherwise disqualified.



State of New Mexico

Water Quality Control Commission

This certifies that

David Hunter

has met the requirements for utility operator certification adopted by the New Mexico Water Quality Control Commission pursuant to the "Utility Operator Certification Act", and is hereby certified as a Utility Operator authorized to operate and maintain

Water Supply level 3

Date of issue: November 08, 2023

Certified at this level since: October 10, 2023

EXPIRES: July 31, 2025

For the Chairman, WQCC

Operator ID: NM 20036